

TAA 21-5A / D214793
Computer Room Renovations at the
Administrative Headquarters at MP 141.92
in Albany County

QUESTIONS AND ANSWERS

Q1. Would the Authority accept a proposal for alternative UPS Equipment?

A1. The specifications requires Vertiv/Liebert; Model 51SA075EBA. No substitutions or equivalent models will be permitted.

4/20/2021

Q2: Is there going to be an addendum or an extension of this project?

A2: The Computer Room Renovation project is of high importance to the Authority and we have not received any additional requests for a time extension. The original schedule will be maintained.