

TAS 25-5B / D215007
Rehabilitation of the I-90 Ramp Bridge over
North Genesee Street at MP 233.27 in Oneida County

QUESTIONS AND ANSWERS

January 27, 2025

- Q1. Note - "Repair of Nicks, Scrapes and Gouges" does not point out a designated pay item. Please advise. Clarify pay item for above referenced note.
- A1. The Repair of Nicks, Scrapes and Gouges, and applicable notes on Dwg. GN-02 only applies to the proposed steel repair areas designated in the contract plans. Repair of Nicks, Scrapes and Gouges shall be included in the lump sum bid cost for item 564.0501 - Structural Steel - Type 1, only at those designated repair areas.