

TAS 26-10A / D215078
Replace Waterline at the Port Byron Service Area, MP 310.2 EB
in Cayuga County

QUESTIONS AND ANSWERS

December 16, 2025

- Q1. Will there be a pre-bid meeting for this project?
- A1. There will not be a pre-bid meeting for this project.
- Q2. The report prepared by Colliers classifies the pipe as HDPE, but the plans indicate DIP. Which is preferred?
- A2. While the plans indicate DIP, HDPE is considered a reasonable alternative here.
- Q3. I am unable to send an email to Nick Tario, the registered Architect at the Thruway Authority for this project. How can I reach him?
- A3. Mr. Tario's correct email address is: Nicholas.Tario@thruway.ny.gov.